


BOREHOLE WATER ANALYSIS FOR ETHANOL MILL SITE

Receipt date	02.08.2015	Type	GROUND WATER BOREWELLWATER:ELU
No.	01	Collected by	PARTY

D Analysis Report

Sr. No	Parameters	Value
1.	pH	6.70
2.	Turbidity(NTU)	Nil
3.	Total Alkalinity as CaCO ₃ (mg/Litre)	55.00
4.	Total Hardness as CaCO ₃ (mg/Litre)	45.00
5.	Chlorides as Cl (mg/Litre)	12.40
6.	Total Dissolved Solids(mg/Litre)	120.00
7.	Iron as Fe(mg/Litre)	0.011
8.	Sulphates as SO ₄ (mg/Litre)	2.11
9.	Total Suspended Soilds(mg/Litre)	3.49
10.	Colloidal Silica (mg/Litre)	Nil
11.	Reactive Silica(mg/Litre)	26.20
12.	E.Coli (per 100 ml)	Present


FOR HYDROTECH LABORATORY**RIVER WATER ANALYSIS FOR PRESSCANE**

Receipt date	02.08.2015	Type	GROUND WATER BOREWELLWATER:ELU
No.	01	Collected by	PARTY

D Analysis Report

Sr. No	Parameters	Value
1.	pH	6.70
2.	Turbidity(NTU)	Nil
3.	Total Alkalinity as CaCO ₃ (mg/Litre)	55.00
4.	Total Hardness as CaCO ₃ (mg/Litre)	45.00
5.	Chlorides as Cl (mg/Litre)	12.40
6.	Total Dissolved Solids(mg/Litre)	120.00
7.	Iron as Fe(mg/Litre)	0.011
8.	Sulphates as SO ₄ (mg/Litre)	2.11
9.	Total Suspended Soilds(mg/Litre)	3.49
10.	Colloidal Silica (mg/Litre)	Nil
11.	Reactive Silica(mg/Litre)	26.20
12.	E.Coli (per 100 ml)	Present


FOR HYDROTECH LABORATORY